




Serial number:
IDSL0270A0050UH

Insulation system Class E
Terminals are high current copper lug terminations
IP rating IP00

Dimensions in mm										
Reference	A	B	C	D	E	F	G	H	J	KG
IDSL0270A0050UH	240	110	260	210	200	170	190	8	10	14.8

Drawing Number TWC 6518053		
Title	50uH 270A line reactor	
Project	Wound components	
Drawn Date	11/08/2015	
Sheet Number	1	Of 1
Drawn By	RDT	
Scale	NTS	Revision 1
Company Name		
The Inverter Drive Supermarket		
Unit 5 Battle Brook Drive		
Chipping Campden		
Gloucestershire UK. GL55 6JX		
Telephone No	+44 (0) 1386 848830	
Email Address	sales@inverterdrive.com	
Web Address	www.inverterdrive.com	