
Serial number:

IDSL0680A0035UH

Insulation system Class E
Terminals are high conductivity copper bus bar
IP rating IP00

All units are fitted with lifting eyes for easy mounting to panel backplates



Dimensions in mm										
Reference	A	B	C	D	E	F	G	H	J	KG
IDSL0680A0035UH	420	430	180	240	300	355	380	15	2 x 12mm	59.0

Drawing Number	TWC 6518046		
Title	35uH 680A line reactor		
Project	Wound components		
Drawn Date	12/08/2015		
Sheet Number	1	Of	1
Drawn By	RDT		
Scale	NTS	Revision	1

Company Name
The Inverter Drive Supermarket

Unit 5 Battle Brook Drive
Chipping Campden
Gloucestershire UK. GL55 6JX

Telephone No +44 (0) 1386 848830
Email Address sales@inverterdrive.com
Web Address www.inverterdrive.com