
Serial number:

IDSL0830A0015UH

Insulation system Class E
Terminals are high conductivity copper bus bar
IP rating IP00

All units are fitted with lifting eyes for easy mounting to panel backplates



Dimensions in mm										
Reference	**A**	**B**	**C**	**D**	**E**	**F**	**G**	**H**	**J**	**KG**
IDSL0830A0015UH	**420**	**430**	**180**	**240**	**300**	**355**	**380**	**15**	**2 x 12mm**	**47.0**

Drawing Number	TWC 6518060		
Title	15uH 830A line reactor		
Project	Wound components		
Drawn Date	11/08/2015		
Sheet Number	1	Of	1
Drawn By	RDT		
Scale	NTS	Revision	1

Company Name
The Inverter Drive Supermarket

Unit 5 Battle Brook Drive
Chipping Campden
Gloucestershire UK. GL55 6JX

Telephone No +44 (0) 1386 848830
Email Address sales@inverterdrive.com
Web Address www.inverterdrive.com