



PROJECTION



4-OFF M8
REMOVABLE EYENUTS-
(VERTICAL LIFT ONLY)



COPPER FLAGS ARE TO BE
INSULATED AS ABOVE
(NO INSULATION WITHIN 25mm
OF HOLES IN COPPER FLAGS)



MOUNTING BASE AND 4-OFF
FIXING POINTS TO BE FREE
FROM ANY VARNISH
OR OTHER INSULATING MATERIAL.
(I.E. SHADED AREA AS DETAILED ABOVE)
BASE OF ANGLES TO BE FREE
OF VARNISH (I.E. FINISH TO BARE METAL)

BASE OF ANGLES
TO BE FREE OF VARNISH
(LINISH TO BARE METAL)

ISSUE	DESCRIPTION	APPROVED	DATE	TITLE	DRAWING No.			DATE
2	D.A 05093	P.S	22/08/01	OUTLINE DRAWING 480A, 50microH CHOKE. DESIGN No 34638 (PART No : C0389936U402)	DRAWN	CHECKED	APPROVED	06.03.01
3	D.A 05187	S.D.	16/10/01		P.S			
4	REFER TO DA05323.	N.G./S.D.	18/03/02		SKOT TRANSFORMERS LTD. TEL 01684 569104 FAX 01684 565766 UPPER COLWALL, MALVERN, WORCS WR13 9PL.			
					SKOT TRANSFORMERS LTD. MANUFACTURING TOLERANCES: NO DECIMAL PLACE (0) ±1 ONE DECIMAL PLACE (0.0) ±0.5 UNLESS OTHERWISE STATED. ALL DIMENSIONS IN MM.			