
OPMP-01-Kit Installation Instructions

Cabinet Panel Mounting Kit, OPMP-01

The Control Panel Mounting Platform alows remote mounting of an ACS-CP-C/A operator Panel on a larger enclosure or remotely. The kit maintains UL Type 12 integrity of the mounting location. Adapters, 3 m (10 ft) cable and mounting hardware are included in this kit. With this mounting arrangement, the operator panel is removable identical to a drive-mounted keypad.

Shipping Package Includes:

1. Mounting Template.
2. Cat5 Patch Cable 10 ft.
3. Stainless Steel Compression Bracket.
4. Gaskets (for operator panel).
5. Plastic bag with 6 screws.
6. Panel Platform (Interface board and 2 gaskets installed).
7. Installation Instructions.






1. Take Operator Panel and Gaskets (# 4).



2. Turn your Operator Panel face down and separate ring gasket from middle section.




3. Place the Gasket around the Battery Compartment.



4. Separate square gasket from middle section.



5. Place the Gasket around the Panel Connector.



6. Take the mounting template and make a hole exactly the same size as the template on the door or wall for installation of the Panel Mounting Platform.


3AUA0000013204 / REVB / October 1, 2008

© 2008 ABB Inc. All Rights Reserved.


OPMP-01-Kit Installation Instructions (Cont.)




7. Insert the Panel Platform in the hole.



8. Insert the Stainless Steel Compression Bracket.



9. Align screw openings of the stainless steel bracket in the platform holes with screws. Screw six (6) screws in place.



10. Attach the Cat5 Patch 10 ft Cable from the drive to the top panel connection on the interface board.



11. Attach the Panel Connector from your drive to the Kit.



12. Insert your Operator Panel into the Panel Mounting Platform.

3AUA0000013204 / REVB / October 1, 2008

© 2008 ABB Inc. All Rights Reserved.